

Water Testing Results - NW Regional ESD

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID#	Test Date	Test Result
TECC/Drinking Fountain	6267006-01	9/20/2016	20.4 ppb
TECC/Kitchen sink	6267006-02	9/20/2016	2.4 ppb
Clatsop Service Center/Fountain	6267008-01	9/16/2016	21.4 ppb
Clatsop Service Center/Sink, kitchen	6267008-02	9/16/2016	ND
Clatsop Service Center/Refrigerator H2O dispenser	6267008-03	9/16/2016	ND
Clatsop Service Center/Sink, El wing storage room	6267008-04	9/16/2016	8.6 ppb
Washington Service Center/Tech Warehouse	6267007-01	9/22/2016	ND
Washington Service Center/Lunchroom kitchen	6267007-02	9/22/2016	ND
Washington Service Center/North hall fountain	6267007-03	9/22/2016	ND
Washington Service Center/Board rm. kitchen sink	6267007-04	9/22/2016	ND
Washington Service Center/Ramp hall fountain	6267007-05	9/22/2016	ND
Washington Service Center/Wash. rm. Kitche sink	6267007-06	9/22/2016	ND
Washington Service Center/Custodial storage sink	6267007-07	9/22/2016	7.9 ppb
Washington Service Center/Audiology sink	6267007-08	9/22/2016	ND
BECC/Fountain, main hall TALL	6267018-01	9/23/2016	ND
BECC/Fountain, main hall SHORT	6267018-02	9/23/2016	ND
BECC/Sink, staff kitchen	6267018-03	9/23/2016	ND
HECC/Sink, fabrication rm.	6267017-01	9/16/2016	ND
HECC/Sink, staff lounge	6267017-02	9/16/2016	ND
HECC/Fountain, tall	6267017-03	9/16/2016	ND
HECC/Fountain, low	6267017-04	9/16/2016	ND
Cascade-Pacific/PA fountain 1	6267015-0	9/20/2016	2
Cascade-Pacific/PA fountain 2	6267015-01	9/20/2016	2
Cascade-Pacific/Sink, kitchen	6267015-02	9/20/2016	2
Cascade-Pacific/Sink, breakroom	6267015-03	9/20/2016	2
Cascade-Pacific/Sink, CA laundry	6267015-04	9/20/2016	2
Cascade-Pacific/Fountain, CA	6267015-05	9/20/2016	2
Day Treatment Program/Kitchen sink 1	6267005-01	9/20/2016	ND
Day Treatment Program/Water dispenser 2	6267005-02	9/20/2016	ND
Day Treatment Program/Small kitchen 3	6267005-03	9/20/2016	4.4 ppb
Day Treatment Program/Fountain 4	6267005-04	9/20/2016	ND
Day Treatment Program/Upstairs water dispenser 5	6267005-05	9/20/2016	ND
Day Treatment Program/Upstairs lunhchroom sink 6	6267005-06	9/20/2016	ND
Columbia Service Center, Warren/Sink, classroom	6267014-01	9/16/2016	ND
Columbia Service Center, El/Sink, kitchen	6267011-01	9/16/2016	3.4
Columbia Service Center, Clatskanie/Sink, classroom	6267010-01	9/20/2016	ND
Columbia Service Center, Clatskanie El/Sink, kitchen	6267012-01	9/16/2016	ND
Seaside El Portable/Sink, bathroom	6267009-01	9/15/2016	ND
Levi Anderson School/Fountain main floor	6165014-01	6/10/2016	ND
Levi Anderson School/Fountain 3rd floor	6165014-02	6/10/2016	ND

Levi Anderson School/Sink, 1st floor class 5	6165014-03	6/10/2016	ND
Levi Anderson School/Sink, basement boys BR	6165014-04	6/10/2016	ND
Levi Anderson School/Sink, 3rd floor staff rm.	6165014-05	6/10/2016	ND

ND = Non Detect - Lead level is below the set detection limits