



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016  
Received: 09/23/2016  
Sampled By: Annie Dolber  
Work Order: 6267008

**C** **NWRES**  
**L** Attn: Sharon Meeuwesen  
**I** 5825 NE Ray Circle  
**E** Hillsboro OR, 97124  
**N** Phone: (503) 614-1428  
**T**

**Project:** NWRES  
Project # : N/A  
Sample Type :

Sampling Location: Clatsop Svc. Ctr

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6267008-01</b>	<b>Sample Name:</b> Fountain/Hallway <b>Sampled:</b> 9/16/16 7:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	21.4	ppb	2.0	20 ppb	10/28/16 16:06 <b>MCLE</b>
<b>6267008-02</b>	<b>Sample Name:</b> Sink/Kitchen <b>Sampled:</b> 9/16/16 7:35		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
<b>6267008-03</b>	<b>Sample Name:</b> Refrigerator H2O Dispenser <b>Sampled:</b> 9/16/16 7:37		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
<b>6267008-04</b>	<b>Sample Name:</b> Sink/ E1 Wing Storage Room <b>Sampled:</b> 9/16/16 7:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	8.6	ppb	2.0	20 ppb	10/28/16 16:06

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director

