



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/23/2016
Sampled By: Michelle Guthrie
Work Order: 6267005

C **NWRES**
L Attn: Sharon Meeuwse
I 5825 NE Ray Circle
E Hillsboro OR, 97124
N Phone: (503) 614-1428
T

Project: NWRES
Project # : N/A
Sample Type :

Sampling Location: Day Treatment Program

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6267005-01	Sample Name: Kitchen Sink - 1 Sampled: 9/20/16 6:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267005-02	Sample Name: Water Dispencer - 2 Sampled: 9/20/16 6:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267005-03	Sample Name: Small Kitchen - 3 Sampled: 9/20/16 6:47		Matrix: Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	10/28/16 16:06
6267005-04	Sample Name: Fountain - 4 Sampled: 9/20/16 6:45		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267005-05	Sample Name: Upstairs - Water Dispencer - 5 Sampled: 9/20/16 6:48		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267005-06	Sample Name: Upstairs - Lunchroom Sink - 6 Sampled: 9/20/16 6:48		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

