



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/23/2016
Sampled By: Becky Heikkila
Work Order: 6267009

C **NWRESD**
L Attn: Sharon Meeuwse
I 5825 NE Ray Circle
E Hillsboro OR, 97124
N Phone: (503) 614-1428
T

Project: NWRESD
Project # : N/A
Sample Type :

Sampling Location: Seaside El
Sample Matrix: Water

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6267009-01	Sample Name: Bathroom Portable		Matrix: Water				
	Sampled: 9/15/16 7:50						
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

