



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016  
Received: 09/23/2016  
Sampled By: Tammee Meneghin  
Work Order: 6267006

**C** **NWRESD**  
**L** Attn: Sharon Meeuwesen  
**I** 5825 NE Ray Circle  
**E** Hillsboro OR, 97124  
**N** Phone: (503) 614-1428  
**T**

**Project:** NWRESD  
Project # : N/A  
Sample Type :

Sampling Location: TECC

## Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6267006-01</b>	<b>Sample Name:</b> Drinking Fountain <b>Sampled:</b> 9/20/16 7:40		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>20.4</b>	ppb	2.0	20 ppb	10/28/16 16:06 <b>MCLE</b>
<b>6267006-02</b>	<b>Sample Name:</b> Kitchen Sink <b>Sampled:</b> 9/20/16 7:41		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	10/28/16 16:06

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

