

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/23/2016
Sampled By: Sharon Meeuwsen
Work Order: 6267007

C **NWRES**
L Attn: Sharon Meeuwsen
I 5825 NE Ray Circle
E Hillsboro OR, 97124
N Phone: (503) 614-1428
T

Project: NWRES
Project # : N/A
Sample Type :

Sampling Location: WSC


Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6267007-01	Sample Name: Tech Warehouse Sampled: 9/22/16 6:34						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-02	Sample Name: Lunchroom Kitchen Sampled: 9/22/16 6:39						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-03	Sample Name: North Hallway Fountain Sampled: 9/22/16 6:41						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-04	Sample Name: Boardroom Sink Sampled: 9/22/16 6:44						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-05	Sample Name: Ramp Hall Fountain Sampled: 9/22/16 6:47						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-06	Sample Name: Washington Rm Sink Sampled: 9/22/16 6:49						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06
6267007-07	Sample Name: Custodial Storage Sink Sampled: 9/22/16 6:56						Matrix: Water
+Lead	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	10/28/16 16:06
6267007-08	Sample Name: Audiology Sink Sampled: 9/22/16 6:59						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	10/28/16 16:06

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 11/01/2016
Received: 09/23/2016
Sampled By: Sharon Meeuwsen
Work Order: 6267007

C **NWRESD**
L Attn: Sharon Meeuwsen
I 5825 NE Ray Circle
E Hillsboro OR, 97124
N Phone: (503) 614-1428
T

Project: NWRESD
Project # : N/A
Sample Type :

Sampling Location: WSC

Lab Number

Approved by: _____



Adriana Gonzalez-Gray
Laboratory Director

