

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 06/17/2016  
Received: 06/13/2016  
Sampled By: Tulla Stocker  
Work Order: 6165014

**C** Apex Environmental  
**L** Attn: Tulla Stocker  
**I** PO Box 1445  
**E** Wilsonville OR, 97070  
**N** Phone: (503) 682-9737  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location: Levi Anderson School

**Lab Number**


Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6165014-01</b>	<b>Sample Name:</b> SM-B01 - Main Floor Near Class 2 <b>Sampled:</b> 6/10/16 7:00						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/15/16 16:29
<b>6165014-02</b>	<b>Sample Name:</b> SM-B02 - 3rd fl. Near Class 7 <b>Sampled:</b> 6/10/16 7:03						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/15/16 16:29
<b>6165014-03</b>	<b>Sample Name:</b> SM-B03 - 1st Floor Class 5 Sink <b>Sampled:</b> 6/10/16 7:05						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/15/16 16:29
<b>6165014-04</b>	<b>Sample Name:</b> SM-B04 - Basement Boys BR Sink <b>Sampled:</b> 6/10/16 7:07						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/15/16 16:29
<b>6165014-05</b>	<b>Sample Name:</b> SM-B05 - 3rd Floor Staff R. Sink <b>Sampled:</b> 6/10/16 7:12						<b>Matrix:</b> Water
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/15/16 16:29

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

+All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is an action level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

  
Adriana Gonzalez-Gray  
Laboratory Director

**Levi Anderson School**  
**16535 SW Tualatin Valley Highway**  
**Beaverton, OR 97006**

DATE	SAMPLE NUMBER	TIME COLLECTED	FAUCET TYPE	LOCATION	LEAD INITIAL
6/10/2016	SM-B01	7:00 AM	Drinking fountain	Main floor near classroom 2	ND
6/10/2016	SM-B02	7:03 AM	Drinking fountain	Third floor near classroom 7	ND
6/10/2016	SM-B03	7:05 AM	Sink	First floor classroom 5	ND
6/10/2016	SM-B04	7:07 AM	Sink	Basement boys restroom sink	ND
6/10/2016	SM-B05	7:12 AM	Sink	Basement boys restroom sink	ND
Sample Type:					
Initial Screening: Sample collected after water has remained in system for at least 8 hours. Indicates "worst case scenario" of fountain type.					
ND: None Detected					

Apex Environmental Consulting Services, Inc.  
 PO Box 1445  
 Wilsonville, OR 97070  
 (503)682-9737

**Levi Anderson School  
16535 SW Tualatin Valley Highway  
Beaverton, OR 97006**

DATE	SAMPLE NUMBER	TIME COLLECTED	FAUCET TYPE	LOCATION	LEAD INITIAL
6/10/2016	SM-B01	7:00 AM	Drinking fountain	Main floor near classroom 2	ND
6/10/2016	SM-B02	7:03 AM	Drinking fountain	Third floor near classroom 7	ND
6/10/2016	SM-B03	7:05 AM	Sink	First floor classroom 5	ND
6/10/2016	SM-B04	7:07 AM	Sink	Basement boys restroom sink	ND
6/10/2016	SM-B05	7:12 AM	Sink	Basement boys restroom sink	ND

Sample Type:

Initial Screening: Sample collected after water has remained in system for at least 8 hours. Indicates "worst case scenario" of fountain type.

ND: None Detected


Apex Environmental Consulting Services, Inc.  
PO Box 1445  
Wilsonville, OR 97070  
(503)682-9737

